



TYPICAL NOTES.

1. FLOOR SLAB THICKNESS IS 9" AT BASEMENT - 9 1/2" AT LOBBY LEVEL - 8" TYP FLOORS & ROOF.
2. F-4000 PSI UP TO 8" TYP FLOORS & ROOF - 3,000 PSI REMINDER
3. REINF SHOWN IS ALL TOP REINF (U.O.N)
4. BOTTOM REINF SHALL BE #4 @ 13" BOTTOM EA. WAY IN ADDITION TO ANY INDICATED BOTTOM STEEL.
5. AT LEAST 25% OF ALL COLUMN STRIP REINF. SHALL BE CENTERED OVER THE COL. AS EXPLAINED IN TYP. PLATE DETAIL - SEE SHEET S11
6. FOR REINF. AROUND OPENINGS SEE TYP. DET. SHEET S11
7. PLACE 2#4 UNDER ALL BLOCK WALLS.
8. TEMP REINF. AT CANTILEVER #4 @ 13" TOP
9. DO NOT CONSTRUCT MASONRY WALLS UNTIL THE ENCLOSING STRUCTURE HAS BEEN ERRECTED.

SECOND FLOOR
FRAMING PLAN
SCALE: 1/8"=1'-0"

WILLIAM M. FRIEDMAN & ASSOCIATES
ARCHITECTS, INC.

WMP

138 S.E. 14TH LANE

CHAMPLAIN TOWERS SOUTH

A 135 UNIT CONDOMINIUM

BREITERMAN JURADO & ASSOCIATES

CONSULTING ENGINEERS

420 SOUTH DIXIE HIGHWAY CORAL GABLES FLORIDA 33146

COMM. NO. DATE 8/22/79 SHEET NO.

REV. 56 OF 14